

"DETECTSOUND" and "dBOHS": A software package for the analysis of health and safety in noisy workplaces

Chantal Laroche¹, Raymond Hétu², Hung Tran Quoc², Jean-Marc Rouffet³

¹Sonométrie Inc., 5757 Decelles Ave., Suite 406, Montréal (Québec) H3S 2C3

²Groupe d'Acoustique de l'Université de Montréal, C.P. 6128, Succ. A, Montréal (Québec) H3S 2C3

³01 dB, 113, rue du 1er mars, Villeurbanne, France

1. Introduction

Every year serious injuries occur in noisy workplaces because a warning signal is not heard. Very few practical tools allowing direct prediction of the ability to detect acoustic signals in noisy environments are available. The Groupe d'Acoustique de l'Université de Montréal (GAUM) has developed a computerized model called DETECTSOUND which runs on an IBM-PC compatible and which can predict the capability of workers to detect auditory warning signals in noise. To run DETECTSOUND, it is necessary to obtain 1/3 octave band levels at each work station. dBOHS was designed to obtain this information from a recording made on the site using a digital audio-tape recorder and a hand-held controller. The following paragraphs present the main characteristics of each software.

2. DETECTSOUND software

DETECTSOUND allows user to:

- 1) Specify the characteristics of warning sounds to be installed in a workplace;
- 2) Evaluate the effectiveness of the warning sounds in use in a workplace.

The foundations of the model have been presented in a previous paper ¹.

DETECTSOUND takes into account the following information:

- the background noise at each workstation (1/3 octave band levels from 25 to 12 500 Hz);
- the hearing protectors worn by a standard individual or by specific individuals (attenuation in dB from 63 to 8000 Hz);
- the audiogram of a standard individual or the actual individuals assigned to a workstation (hearing thresholds from 125 to 8000 Hz);
- all warning sounds that can be heard at the station (1/3 octave band levels from 25 to 12 500 Hz).

A standard individual refers to five different stages of hearing loss, stage 0 meaning normal hearing for a 50 years old man and stage 4 meaning an advanced level of noise-induced hearing loss.

The loss of frequency selectivity is also taken into account in the software. It is statistically related to the loss of sensitivity. In fact, the user do not have to enter this information. It is automatically computed based on the hearing thresholds.²

When these informations are entered in their specific table forms and computed together, the results are displayed in a graphic or a table form. Figure 1 presents an example of a graphic display.




Fig.1 Graphical display of the design window for a particular workstation.

The frequency content is presented on the x axis and the level of each 1/3 octave band of the noise or the warning sound is on the y axis. The full horizontal line corresponds to the background noise level at the loading workstation of the expedition zone. The vertical lines correspond to the spectral content of the bell heard at this workstation. The dark zone represents the design window, i.e. the spectral and level region in which at least two spectral lines of a warning sound should be in order to attract attention and be recognized among different warning sounds. In this example, the bell should be well recognized by 50 years old workers (stage 0 has been used in this example) because each of the four lines are inside or at the borders of the design window. If all the spectral lines would have been below the design window, this would have meant that the spectral content of the warning sound should have been changed or the level increased. If the lines would have been over the design window, this would have meant that the warning sound level would have been too high and could have caused hearing damage, interference with communication or a startle reaction.

3. dBOHS software

dBOHS has been developed to help health and safety professionals to make complete, rapid and automated noise measurements. It gives directly and simultaneously the noise dosis, the temporal evolution (short L_{eqs} , L_p) and the spectral content (in octave and 1/3 octave band levels) of the background noise and of the warning sounds. The temporal evolution of each 1/3 octave band levels is also available. These parameters are useful to evaluate the risk of acquiring hearing loss and the audibility of warning sounds in workplaces.

Recordings of background noise and warning sounds are made with a special controller plugged into a digital audio-tape recorder (DAT) at each workstation. A type 1 microphone is plugged into the controller which sends signals (calibration, sampling, pause) to the second channel of the DAT. These signals are later used by dBOHS to automatically analyse the recordings. This method is presently used by Hydro-Quebec to evaluate the noise emitted by transformer stations^{3,4} and saves a lot of time to the user.

The values given by dBOHS can be directly transferred to DETECTSOUND and synthesized on a personalized form like the one presented on figure 2.

4. Conclusion

The ultimate goal of DETECTSOUND and dBOHS is to supply practical, reliable and rapid means for health and safety personnel to assess the audibility of warning sounds and the risk of acquiring hearing loss. Both software run on IBM-PC compatibles and are user-friendly. GAUM is now working on an upgraded version of DETECTSOUND to allow users to enter individual data on frequency selectivity.

Acknowledgments

DETECTSOUND development has been funded by IRSST.

References

1. Laroche, C., Tran Quoc, H., Hétu, R. and McDuff, S. (1991). "Detectsound": A computerized model for predicting the detectability of warning signals in noisy workplaces. Applied Acoustics 32, 193-214.
2. Laroche, C., Hétu, R., Tran Quoc, H., Josserand, B., Glasberg, B. (1992). Frequency selectivity in workers with noise-induced hearing loss. Submitted for publication.
3. Gosselin, B., Fortin, J., L'Espérance, A. (1992). Measurement of noise emitted by electrical substations- Part I: Measurement method. Inter-Noise, Toronto, 771-774.
4. Laroche, C., Rouffet, J.M., Gosselin, B., Fortin, J. (1992). Measurement of noise emitted by electrical substations- Part II: Measurement system. Inter-Noise, Toronto, 775-78.


SONOMETRIC	CLIENT :	ANNEXE
5757 Decelles Bureau 514	SITE :	
MONTREAL QUEBEC H3S 2C3	OBSERVATIONS :	
tél : (514) 345-0894	AFFAIRE : 5 dec 1991	

Tableaux de Résultats (Fichier : C:\FRANCAIS\c2enc512.LEQ)

Point de Mesure (N° 4): dans le plan
enceinte chaîne 2, 47:40-48:00
conditions normales, 1 l

L_{eq} = 90.5 dBA
Min. = 88.1 dBA
Max. = 99.7 dBA
Crête = 115.5 dBL

Evol. Temporelle $L_{eq}(125\text{ ms})$ en dBA



Analyse Fréquentielle (spectre moyen dBLin)




Fig.2 Example of a dBOHS form. Table of results, temporal evolution and spectral content.